

Evidence of Performance

Burglar resistance

Test Report

No. 15-000703-PR02

(PB-C01-05-en-02)



Client ELVIAL S.A.
Aluminium Extrusion
25th Km national road
Thessaloniki
61100 Kilkis
Greece

Product Single leaf burglar resistant doorset

Designation Xclusive 88

Overall dimensions (W x H) 1,000 mm x 2,248 mm

(Frame) Material, System Aluminium, Xclusive 88

Attack side Closing face as per EN 12519

Type of opening single leaf

Glazing none glazing

quintuple locking 2091381 Winkhaus GmbH as per DIN 18251 Klasse 4, continuous strike plate 2548854 Winkhaus GmbH, double cylinder RPE 01 BN3 Winkhaus GmbH as per DIN EN 1303 Clause 7, Class 4, short plate 811 AZ Erich Diekmann GmbH as per DIN EN 1906 Class 3, three-part door hinge 4, Dr. Hahn as per EN 1935, 4 pieces pin retention Dr. Hahn GmbH, 1 piece air gap restrictor Winkhaus GmbH

Hardware According to installation instructions from company
Installation ELVIAL S.A. Aluminium Extrusion

Special features -/-

Basis

DIN EN 1627 : 2011
Doors, windows, curtain walling, grilles and shutters – Requirements and classification
DIN EN 1628 : 2011
DIN EN 1629 : 2011
DIN EN 1630 : 2011

Replaced Test Report
No. 15-000703-PR02 (PB-C01-05-en-01) dated 30.9.2015

Representation



Instructions for use

This test report serves to demonstrate burglar resistance.

Validity

The data and results given refer solely to the tested and described specimen. Testing to burglar resistance does not allow any statement to be made on any further characteristics of the present structure regarding performance and quality.

In deviation from the tested type, the following dimensional changes are permitted:
Width +10% and -20%
Height +10% and -20%

Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies.

The cover sheet can be used as an abstract.

Contents

The report contains a total of 36 pages

- 1 Object
- 2 Procedure
- 3 Detailed results
Annex 1 (7 pages)
Annex 2 (2 pages)
Annex 3 (12 page/s)

Burglar resistance



RC 3

ift Rosenheim

09.11.2015

Robert Krippahl, Dipl.-Ing. (FH)
Operating Product Officer
Building Components

Simon Stürer
Operating Testing Officer
Security/Safety Testing